

1. IF PULLBOX IS EXISTING, THE GROUT SHALL BE REPAIRED.
2. IF RIGID STEEL CONDUIT IS PRESENT, BONDING SHALL BE AS PER CITY OF SAN JOSE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
3. ALL WORK SHALL COMPLY WITH CITY OF SAN JOSE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
4. SPECIFIC SPlicing REQUIREMENTS DEPEND ON FIELD CONDITIONS.
5. IF GROUND ROD IS NOT PRESENT DUE TO FIELD CONDITIONS AND REQUIREMENTS, BONDING SHALL BE AS PER CITY OF SAN JOSE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
6. PROVIDE 3' OF SLACK IN ALL CONDUCTORS IN ACCORDANCE WITH SPECIFICATIONS. (SLACK NOT SHOWN).
7. SEE NOTES DRAWINGS E-04, E-05, E-06, AND E-37.